

Long Name	Short Name	Data Type	Object ID	Attribute ID	Modbus Address	N2 Point Type	N2 Point Address	BACoid	Modify	Default/ IP Default Value	IP Min Value	IP Max Value	IP Units	Default/ SI Default Value	SI Min Value	SI Max Value	SI Units	Enum Set
Unit Status	Unit-S	MV	1	7000	280	ADI	1	29803	Read Only									0=Idle/1=SD Alarm/2=Purge Command/3=Self Test/4=Morning Warm Up/5=Air Tempering/6=Dehumidification/7=Heating/8=Cooling/9=Economizer/10=Fan Only/11=Comfort Ventilation/12=Startup Delay
Unit Name	Name	SV	1	7001				29804	Read/Write			30					30	
Unit Model Number	Model#	SV	1	7002				29805	Read/Write	RTUxxxxx		40					40	
Unit Serial Number	Serial#	SV	1	7003				29806	Read/Write			40					40	
Firmware Version	FirmVer	SV	1	7004				29807	Read Only			30					30	
Firmware Status	Firm-S	MV	1	7005					Read Only									0=Firmware Versions OK/1=Firmware Versions Do Not Match the Package
Heating Control Type	Htg-Type	MV	1	7006				29501	Read/Write									0=Staged/1=Proportional
Exhaust Type	ExFTyp	MV	1	7008	412	ADI	129	29503	Read/Write									0=None/1=Non-Modulating/2=Modulating Damper/3=Variable Frequency Fan
UCB 24VAC Input	UCB24VForOutp	AV	1	7009					Read Only				V				V	
Cancel ASCD Timers	N/A	MV	1	7010					Read/Write	Off								Off/On
Reset Lockouts	ResetLO	MV	1	7011	80	ADI	2	29826	Read/Write	Off								Off/On
Outputs Disabled Due to Low Input Voltage	N/A	MV	1	7012					Read Only									No/Yes
Outputs Limited Due to Low Input Voltage	N/A	MV	1	7013					Read Only									No/Yes
Model Name	ModelName	SV	1	7014					Read Only			30					30	
CCS Online	N/A	MV	1	7015					Read/Write	No								No/Yes
Rooftop Controller Type	CntrlType	MV	1	7017					Read/Write	Constant Volume								0=Changeover Bypass/1=VAV/2=Constant Volume/3=TEC
Rooftop Equipment Type	EquipType	MV	1	7018					Read/Write	RTU								0=Unknown/1=RTU/2=Split/3=HeatPump
Unit Enable	UnitEn	MV	1	7019	411	ADI	128	29896	Read/Write	Enable								Shutdown/Enable
SZ VAV Enabled	SZVAVEn	MV	1	7020	399	ADI	118	29908	Read/Write									Off/On
Hardware Reset	HdwrReset	MV	1	7021	126	ADI	109	29909	Read/Write	No								No/Yes
Software Version	N/A	AV	1	7022	0				Read Only	12292								
Event 1 Value	Event1Value	AV	1	7023	825			29938	Read Only									
Event 2 Value	Event2Value	AV	1	7024	827			29940	Read Only									
Event 3 Value	Event3Value	AV	1	7025	829			29942	Read Only									
Event 4 Value	Event4Value	AV	1	7026	831			29944	Read Only									
Event 5 Value	Event5Value	AV	1	7027	833			29946	Read Only									
Event 1 Set	Event1Set	AV	1	7028	824			29939	Read Only									
Event 2 Set	Event2Set	AV	1	7029	826			29941	Read Only									
Event 3 Set	Event3Set	AV	1	7030	828			29943	Read Only									
Event 4 Set	Event4Set	AV	1	7031	830			29945	Read Only									
Event 5 Set	Event5Set	AV	1	7032	832			29947	Read Only									
HVAC Space	N/A	MV	1	7036					Read Only									No/Yes
High Alarm Text	N/A	MV	1	7037	834				Read Only									
Low Alarm Text	N/A	MV	1	7038	835				Read Only									
High Alarm Text	N/A	MV	1	7039	836				Read Only									
Low Alarm Text	N/A	MV	1	7040	837				Read Only									
High Alarm Text	N/A	MV	1	7041	838				Read Only									
Low Alarm Text	N/A	MV	1	7042	839				Read Only									
Unique Equipment Identifier	N/A	MV	1	7043					Read/Write									0=Standard / 1=Tandem Cir1 With 2 Stage Cir2 / 2= 2 Stage Cir1 With 2 Stage Cir2 / 3=2 Stage Cir1 With Single Cir2 / 4=Tandem Cir1 With Single Cir2 / 5=Inverted Single Cir1 With Single Cir2
Serial Flash Size	Serial Flash Size	SV	1	7044														
Y1 - Thermostat	Y1-Tstat	MV	2	7000	281	BI	1	29504	Read Only									0=Off/1=On
Y2 - Thermostat	Y2-Tstat	MV	2	7001	282	BI	2	29505	Read Only									Off/On
Y3 - Thermostat	Y3-Tstat	MV	2	7002	283	BI	3	29506	Read Only									Off/On
Y4 - Thermostat	Y4-Tstat	MV	2	7003	284	BI	4	29507	Read Only									Off/On
W1 - Thermostat	W1-Tstat	MV	2	7004	285	BI	5	29508	Read Only									Off/On
W2 - Thermostat	W2-Tstat	MV	2	7005	286	BI	6	29509	Read Only									Off/On
W3 - Thermostat	W3-Tstat	MV	2	7006	287	BI	7	29510	Read Only									Off/On
G - Thermostat	G-Tstat	MV	2	7007	288	BI	8	29511	Read Only									Off/On
Local Occupancy Input - Thermostat	Occ-Tstat	MV	2	7008				29512	Read Only									0=On / 1=Off
X-OUT	X-Out	MV	2	7009	289	BO	1	29513	Read Only									Off/On
Thermostat Only Control Enabled	Tstat-Only	MV	2	7010	413	BI	42	29514	Read/Write	Yes								No/Yes
Fan Status	Fan-S	MV	3	7000	302	ADI	23	29550	Read Only									0=Off-Idle / 1=On-Purge / 2=On-Gas Valve or Limit Fault / 3=On-Defrost / 4=On-Thermostat Request / 5=On-Fan Off Delay For Cool / 6=On-Fan Off Delay For Heat / 7=On-Continuous Fan Occupied Operation / 8=On-Normal Command / 9=Off-Exceeding Duct Pressure Shutdown SP / 10=Off-Low Voltage / 11=Off-Fan Overload Lockout / 12=Off-Fan VFD Fault / 13=Off-Hot Water Freeze Stat / 14=Off-Air Proving Switch / 15=Off-Minimum Off Delay / 16=Off-Fan On Delay For Heat / 17=Off-Fan Off Delay For Cool
Fan % Command	FanVFD	AV	3	7001	157	AO	1	29551	Read Only			%					%	
Fan VFD Fault	FanVFDfIt	MV	3	7002	303	BI	10	29552	Read Only									0=Normal/1=Alarm
Fan Overload	FanOvrload	MV	3	7003	304	BI	11	29553	Read Only									Normal/Alarm
Fan Accumulated Runtime	Fan-RT	AV	3	7004	9	ADF	30	29554	Read/Write		0	10000	hours			0	10000	hours
Fan Control Type	FanCtl-Type	MV	3	7005	400	ADI	119	29555	Read/Write	Single Speed								0=Single Speed / 1=Not Used / 2=Fixed Variable / 3=Variable Speed
Air Proving Switch Setup	APSSetup	MV	3	7006	414	ADI	130	29556	Read/Write	None								0=Constant Volume / 1=Variable Volume / 2=None
Air Proving Switch	APS	MV	3	7007	305	BI	12	29557	Read Only									0=Off / 1=On
Fan On Delay for Cool	FanOnDlyCool	AV	3	7008	90	ADI	24	29558	Read/Write		0	0	30	seconds		0	30	seconds
Fan Off Delay for Cool	FanOffDlyCool	AV	3	7009	415	ADI	131	29559	Read/Write		30	0	255	seconds		0	255	seconds
Fan On Delay for Heat	FanOnDlyHeat	AV	3	7010	416	ADI	132	29560	Read/Write		30	0	30	seconds		0	30	seconds
Fan Off Delay for Heat	FanOffDlyHeat	AV	3	7011	417	ADI	133	29561	Read/Write		120	0	255	seconds		0	255	seconds
Dirty Filter Switch	DFS	MV	3	7012	306	BI	13	29562	Read Only									Normal/Alarm
Fan Command	Fan	MV	3	7013	307	BO	2	29563	Read Only									0=Off / 1=On
Supply Air Temperature	SAT	AV	3	7014	158	AI	3	29564	Read Only				°F					°C
Duct Static Pressure	DctPrs	AV	3	7015	159	AI	4	29565	Read Only				in wc					kPa
Duct Pressure Setpoint	DctPrs-Sp	AV	3	7016	10	ADF	31	29566	Read/Write		1.5	0	5	in wc		0	1.25	kPa
Duct Pressure Shutdown Setpoint	DctShutdownSp	AV	3	7017	11	ADF	32	29567	Read/Write		4.5	0	5	in wc		0	1.25	kPa

Heat Limit3 Switch Lockout	Lim3LO	MV	13	7014	357	ADI	70	29721	Read Only	Normal								Normal/Lockout
VAV Occupied Heating Enabled	HtgOcc-En	MV	13	7015	107	ADI	71	29722	Read/Write	Yes								No/Yes
VAV Occupied Heating Setpoint	VAVHtgOcc-SP	AV	13	7016	39	ADF	118	29723	Read/Write		68	40	85	°F		4	30	°C
Unoccupied Heating Enabled	HtgUnocc-En	MV	13	7017	108	ADI	72	29724	Read/Write	Yes								No/Yes
VAV Unoccupied Heating Setpoint	VAVHtgUnocc-Sp	AV	13	7018	40	ADF	119	29725	Read/Write		60	45	98	°F		7	36	°C
VAV Operating Heating Setpoint	VAVOprHtg-Sp	AV	13	7019	250	ADF	120	29726	Read Only		68			°F				°C
Morning Warmup Enabled	MornW-En	MV	13	7020	109	ADI	73	29822	Read/Write									No/Yes
Morning Warmup/Return Air Temp Setpoint	MornWRAT-Sp	AV	13	7021	41	ADF	121	29823	Read/Write		70	50	85	°F		10	30	°C
VAV Box Heat Command	VAV Box	MV	13	7022	358	BO	9	29727	Read Only									Off/On
CV Occupied Heating Setpoint	CVHtgOcc-SP	AV	13	7023	42	ADF	122	29728	Read/Write		68	46	99	°F		8	37	°C
CV Unoccupied Heating Setpoint	CVHtgUnocc-Sp	AV	13	7024	43	ADF	123	29729	Read/Write		60	45	98	°F		7	36	°C
CV Operating Heating Setpoint	CVOprHtg-Sp	AV	13	7025	251	ADF	124	29730	Read Only		68			°F				°C
Main Valve No Proof Fault	N/A	MV	13	7026					Read Only									Normal/Alarm
Gas Valve 2 No Proof Fault	N/A	MV	13	7027					Read Only									Normal/Alarm
Gas Valve 3 No Proof Fault	N/A	MV	13	7028					Read Only									Normal/Alarm
Main Valve On When Shouldn't Fault	N/A	MV	13	7029					Read Only									Normal/Alarm
Gas Valve 2 On When Shouldn't Fault	N/A	MV	13	7030					Read Only									Normal/Alarm
Gas Valve 3 On When Shouldn't Fault	N/A	MV	13	7031					Read Only									Normal/Alarm
Heating Lockout due to High Outdoor Air Temp	N/A	MV	13	7032					Read Only									Normal/Alarm
Excessive Supply Air Heating Fault	N/A	MV	13	7033					Read Only									0=Normal/1=Drop Stage/2=Wait/3=SAT Unreliable
Morning Cooldown Enabled	MornC-En	MV	13	7034	110	ADI	74	29891	Read/Write									No/Yes
Morning Cooldown/Return Air Temp Setpoint	MornCRAT-Sp	AV	13	7035	44	ADF	125	29892	Read/Write		74	50	85	°F		10	30	°C
Optimal Start Enabled	OptStrt-En	MV	13	7036	111	ADI	75	29893	Read/Write									No/Yes
Occupancy BI Enabled	OccBI-En	MV	13	7037	112	ADI	76	29894	Read/Write									No/Yes
Early Start Period	EarlyStrtPeriod	AV	13	7038	45	ADF	126	29895	Read/Write		60	0	120	minutes		0	120	minutes
Number of Gas Valves Installed	#GasVlvs	AV	13	7039					Read/Write		0	0	3			0	3	
Heating Manual Tuning	HtgManualTune	MV	13	7040					Read/Write									No/Yes
Heating Adaptive Tuning Enable	HtgAdapTunEn	MV	13	7041	114	ADI	78	29881	Read/Write	No								No/Yes
Number of Limit Switches	#LimSwtchs	AV	13	7042	47	ADF	128		Read Only									
DAT Max Heating SP	DATMaxHtgSP	AV	13	7043	75	ADF	161	29905	Read/Write		105	80	110	°F		26.6	43.4	°C
DAT Satisfied SP	DATSatSP	AV	13	7044	76	ADF	162	29906	Read/Write		70	65	75	°F		18.3	23.9	°C
Staged Heating Command	StgHtgCmd	AV	13	7045	264	ADF	166	29923	Read Only					%				%
Proportional Heating Command	PropHtgCmd	AV	13	7046				29924	Read Only					%				%
SZ VAV Occupied Heating Setpoint	SZVAVHtgOcc-SP	AV	13	7047	840	ADF	172	29929	Read/Write		68	46	99	°F		8	37	°C
SZ VAV Unoccupied Heating Setpoint	SZVAVHtgUnocc-Sp	AV	13	7048	841	ADF	173	29930	Read/Write		60	45	98	°F		7	36	°C
SZ VAV Operating Heating Setpoint	OprSZVAVHtg-Sp	AV	13	7049	842	ADF	174	29931	Read Only		68			°F				°C
SZ VAV Heating Load	SZVAVHtgLd	AV	13	7050	437	ADF	187	29936	Read Only					%				%
Operational Error Sigma	HtgManualTune	AV	13	7051					Read/Write		1.399999976	1	2.5	delta °F		0.6	1.5	delta °C
Low Limit Enable	LL_Enable	MV	13	7052					Read/Write									Disable/Enable
Low Limit Upper SAT Setpoint	LL_UpSAT_SP	AV	13	7053					Read/Write		80	65	85	°F		18	30	°C
Low Limit Lower SAT Setpoint	LL_LowSAT_SP	AV	13	7054					Read/Write		65	60	80	°F		15	27	°C
COBP Occupied Heating Enabled	HtgOcc-En	MV	13	7055					Read/Write	Yes								No/Yes
Number of Heating Stages Installed	#HtgStgs	AV	14	7000	430	ADI	141	29731	Read/Write		0	0	3			0	3	
Heating Stage Command 1	H1	MV	15	7000	359	BO	10	29732	Read Only									Off/On
Heating Stage 1 Status	H1-S	MV	15	7001	360	BI	36	29735	Read Only									0=Off-Idle/1=On-Minimum Runtime Timer/2=On-Normal Command/3=Off-Heating Is Disabled/4=Off-Gas Valve Lost Proof/5=Off-Gas Valve False Proof/6=Off-Heating Limit Lockout/7=Off-Anti-Short Cycle Timer/8=Off-Heating Stage Is Disabled
Heating Stage 1 Min On Time Remaining	H1OnTmr	AV	15	7003					Read Only		180			seconds				seconds
Heating Stage 1 Anti-Short Cycle Delay Time Remaining	H1ASCDTmr	AV	15	7004					Read Only		300			seconds				seconds
Heating Stage 1 Accumulated Runtime	H1RunTim	AV	15	7006	48	ADF	129	29738	Read/Write			0	10000	hours		0	10000	hours
Heat Stage 1 Number of Times On	N/A	AV	15	7007					Read/Write			0	2000000			0	2000000	
Heating Stage Command 2	H2	MV	16	7000	361	BO	11	29733	Read Only									Off/On
Heating Stage 2 Status	H2-S	MV	16	7001	362	BI	37	29736	Read Only									0=Off-Idle/1=On-Minimum Runtime Timer/2=On-Normal Command/3=Off-Heating Is Disabled/4=Off-Gas Valve Lost Proof/5=Off-Gas Valve False Proof/6=Off-Heating Limit Lockout/7=Off-Anti-Short Cycle Timer/8=Off-Heating Stage Is Disabled
Heating Stage 2 Min On Time Remaining	H2OnTmr	AV	16	7003					Read Only		180			seconds				seconds
Heating Stage 2 Anti-Short Cycle Delay Time Remaining	H2ASCDTmr	AV	16	7004					Read Only		300			seconds				seconds
Heating Stage 2 Accumulated Runtime	H2RunTim	AV	16	7006	49	ADF	130	29739	Read/Write			0	10000	hours		0	10000	hours
Heat Stage 2 Number of Times On	N/A	AV	16	7007					Read/Write			0	2000000			0	2000000	
Heating Stage Command 3	H3	MV	17	7000	363	BO	12	29734	Read Only									Off/On
Heating Stage 3 Status	H3-S	MV	17	7001	364	BI	38	29737	Read Only									0=Off-Idle/1=On-Minimum Runtime Timer/2=On-Normal Command/3=Off-Heating Is Disabled/4=Off-Gas Valve Lost Proof/5=Off-Gas Valve False Proof/6=Off-Heating Limit Lockout/7=Off-Anti-Short Cycle Timer/8=Off-Heating Stage Is Disabled
Heating Stage 3 Min On Time Remaining	H3OnTmr	AV	17	7003					Read Only		180			seconds				seconds
Heating Stage 3 Anti-Short Cycle Delay Time Remaining	H3ASCDTmr	AV	17	7004					Read Only		300			seconds				seconds
Heating Stage 3 Accumulated Runtime	H3RunTim	AV	17	7006	50	ADF	131	29740	Read/Write			0	10000	hours		0	10000	hours
Heat Stage 3 Number of Times On	N/A	AV	17	7007					Read/Write			0	2000000			0	2000000	
Hydronic Heat Valve % Command	HWV	AV	18	7000	252	AO	2	29741	Read Only					%				%
Hydronic Heat Valve Reverse Acting	HydReverse	MV	18	7001	115	ADI	79	29742	Read/Write	No								No/Yes
Hydronic Heating Stage #1 Supply Air Setpoint	HydH1SA-Sp	AV	18	7002	51	ADF	132	29743	Read/Write		120	80	180	°F		27	82	°C
Hydronic Heating Stage #2 Supply Air Setpoint	HydH2SA-Sp	AV	18	7003	52	ADF	133	29744	Read/Write		150	80	180	°F		27	82	°C
Hydronic Heat SAT Tempering Enabled	SATTempHydHt-En	MV	18	7004	116	ADI	80	29745	Read/Write	No								No/Yes
Hydronic Heat SAT Tempering Setpoint	SATTempHydHt-Sp	AV	18	7005	53	ADF	134	29746	Read/Write		40	40	60	°F		4	15	°C
Hydronic Heat On due to Freeze Stat	N/A	MV	18	7006					Read Only									No/Yes
Hot Water Freeze Stat Opened When It Should Not	N/A	MV	18	7007					Read Only									Normal/Alarm
Economizer Enabled For Operation	Econ-En	MV	19	7000	118	ADI	84	29747	Read/Write	Yes								No/Yes
Economizer Damper % Command	Econ	AV	19	7001	253	AO	3	29748	Read Only					%				%

Comfort Ventilation Status	CVent-S	MV	22	7000				29769	Read Only									State 0/State 1/State 2/State 3/State 4/State 5/State 6/State 7/State 8/State 9/State 10/State 11/State 12/State 13/State 14/State 15/State 16/State 17/State 18/State 19/State 20/State 21/State 22/State 23/State 24/State 25/State 26/State 27/State 28/State 29/State 30/State 31
Comfort Ventilation for Cooling Enabled	CVentCLG-En	MV	22	7001				29770	Read/Write									No/Yes
Comfort Ventilation for Heating Enabled	CVentHtg-En	MV	22	7002				29771	Read/Write									No/Yes
Comfort Ventilation Upper Setpoint	CVentUp-Sp	AV	22	7003				29772	Read/Write			60	85 °F			15	30 °C	
Comfort Ventilation Lower Setpoint	CVentLow-Sp	AV	22	7004				29773	Read/Write			60	85 °F			15	30 °C	
Demand Ventilation Mode of Operation	DVent-Mode	MV	23	7000	120	ADI	93	29765	Read/Write	Disabled								Disabled/Controlled by IAQ/Diff between IAQ and OAQ
Demand Ventilation Maximum Economizer Position	DVentMaxEconPos	AV	23	7001	60	ADF	143	29766	Read/Write			0	100 %			0	100 %	
Demand Ventilation Indoor Air Quality Setpoint	DVentIAQ-Sp	AV	23	7002	61	ADF	144	29767	Read/Write			0	5000 ppm			0	5000 ppm	
Demand Ventilation Differential Setpoint	DVentDiff-Sp	AV	23	7003	62	ADF	145	29768	Read/Write		600	0	5000 ppm			0	5000 ppm	
No Air Quality Control Bad IAQ sensor Fault	N/A	MV	23	7004					Read Only									Normal/Alarm
Fresh Air Intake Setpoint	MOAFlow-Sp	AV	24	7000	69	ADF	154	29795	Read/Write			0	50000 cfm			0	25000 L/s	
Fresh Air Intake Value	Fr Air	AV	24	7001	262	ADF	155	29796	Read Only				cfm				L/s	
Fresh Air Intake Max Sensor Range	MOA-Range	AV	24	7002	70	ADF	156	29797	Read/Write			0	50000 cfm			0	25000 L/s	
Fresh Air Intake Sensor Fault	N/A	MV	24	7003					Read Only									Normal/Alarm
Fresh Air Intake Enable	FrAir-En	MV	24	7004	134	ADI	117	29933	Read/Write									Disable/Enable
Fresh Air Range	Control	AV	24	7005					Read/Write			0	5000 cfm			0	2500 L/s	
Occupancy Input Source	OccSrc	MV	25	7000	290	ADI	3	29515	Read Only									0=Local Input/1=Local Network Sensor/2=BAS Network Request/3=Local Schedule/4=Temporary Occupancy
Operational Occupancy	OprOcc	MV	25	7001	292	ADI	5	29517	Read Only	UnOccupied								0=Occupied/1=UnOccupied/2=Bypass/3=Standby
Occupancy Mode	OccMode	MV	25	7002	82	ADI	6	29518	Read/Write	External								Schedule/External
Network Temporary Occupancy Request	NetTempOcc	MV	25	7003	83	ADI	7	29519	Read/Write	FALSE								False/True
Network Occupancy Request	NetOcc	MV	25	7004	84	ADI	8	29520	Read/Write	Not Set								0=Occupied/1=UnOccupied/2=Not Set
Temporary Occupancy Timeout	TempOccTimeout	AV	25	7005	85	ADI	9	29521	Read/Write		120	30	480 minutes			30	480 minutes	
Operational Space Temperature	OprST	AV	25	7006	135	AI	31	29522	Read Only		70		°F				°C	
Space Temperature Source	STSrc	MV	25	7007	293	ADI	10	29523	Read Only	Unreliable								0=Unreliable/1=Return Air Temp/2=Local Input/3=Network Sensor/4=BAS Override/5=Not Available
Space Temperature Alarm Setpoint Offset	STAlarmOffset	AV	25	7008	274	ADF	2	29524	Read/Write		5	0	25 °F			0	14 °C	
Space Temperature Alarm Time Delay	STAlarmDelay	AV	25	7009	86	ADI	11	29525	Read/Write		60	0	120 minutes			0	120 minutes	
Space Temperature Input	ST	AV	25	7010					Read Only				°F				°C	
Network Override Space Temperature	NetST	AV	25	7011	1	ADF	3	29526	Read/Write			0	100 °F			4	38 °C	
Operational Indoor Air Quality	OprIAQ	AV	25	7012	136	ADF	4	29527	Read Only									ppm
Indoor Air Quality Source	IAQSrc	MV	25	7013	294	ADI	12	29528	Read Only									0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Indoor Air Quality	IAQ	AV	25	7014					Read Only				ppm				ppm	
Indoor Air Quality Sensor Range	IAQRange	AV	25	7015	2	ADF	5	29529	Read/Write			0	5000 ppm			0	5000 ppm	
Network Override Indoor Air Quality	NetIAQ	AV	25	7016	3	ADF	6	29530	Read/Write			0	5000 ppm			0	5000 ppm	
Operational Space Humidity	OprSH	AV	25	7017	137	AI	32	29531	Read Only		0		%RH				%RH	
Space Humidity Source	SHSrc	MV	25	7018	295	ADI	13	29532	Read Only	Unreliable								0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Space Humidity RAH Input	RAH	AV	25	7019	138	AI	1	29828	Read Only				%RH				%RH	
Network Override Zone Humidity	NetSH	AV	25	7020	4	ADF	8	29533	Read/Write			0	100 %RH			0	100 %RH	
Operating Fan Request	OprFanReq	MV	25	7021	296	ADI	14	29534	Read Only	Off								Off/On
Fan Request Source	FanReqSrc	MV	25	7022	297	ADI	15	29535	Read Only	Unreliable								0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Network Override Fan Request	NetFanReq	MV	25	7023	87	ADI	16	29536	Read/Write									Off/On
Operational Space Temperature Setpoint Offset	OprSSO	AV	25	7024	140	ADF	9	29537	Read Only		0		delta °F				delta °K	
Space Temperature Setpoint Offset Source	SSOSrc	MV	25	7025	298	ADI	17	29538	Read Only	Unreliable								0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Space Temp Setpoint Offset Input	SSO	AV	25	7026	141	ADF	10	29539	Read Only				delta °F				delta °K	
Network Override Space Setpoint Offset	NetSSO	AV	25	7027	5	ADF	11	29540	Read/Write		-5	5	delta °F		-3	3	delta °K	
Space Temperature Offset Range	SSORange	AV	25	7028	871	ADF	50	30094	Read/Write				delta deg				delta deg	
Space Temperature Setpoint Offset Range	SSORange	AV	25	7028					Read/Write		3	0	5 delta °F			0	3 delta °K	
Number of Network Sensors Online	#NetSensors	AV	25	7029					Read Only									
Occupancy Input	OCC	MV	25	7030	291	BI	9	29516	Read Only									0=Occupied/1=Unoccupied
Space Temperature Sensor Fault	N/A	MV	25	7031					Read Only									Normal/Alarm
Space Temperature Setpoint Offset Fault	N/A	MV	25	7032					Read Only									Normal/Alarm
Indoor Air Quality Sensor Fault	N/A	MV	25	7033					Read Only									Normal/Alarm
Space Humidity Sensor Fault	N/A	MV	25	7034					Read Only									Normal/Alarm
Netsensor Battery Fault	N/A	MV	25	7035					Read Only									Normal/Alarm
Netsensor Signal Strength Fault	N/A	MV	25	7036					Read Only	Normal								Normal/Alarm
Scheduled Occupancy	N/A	MV	25	7037					Read/Write	Unoccupied								Occupied/Unoccupied
Return Air Temperature	RAT	AV	25	7038	139	AI	2	29764	Read Only				°F				°C	
Return Air Temperature Sensor Fault	N/A	MV	25	7039					Read Only									Normal/Alarm
Temporary Occupancy Input	TempOCC	MV	25	7040	81	ADI	4	29825	Read/Write									Disable/Enable
Space Temperature Cooling Alarm	N/A	MV	25	7041					Read Only									Normal/Alarm
Space Temperature Heating Alarm	N/A	MV	25	7042					Read Only									Normal/Alarm
Load Shed Active	LoadShedEnable	MV	25	7043	127	ADI	110	29883	Read/Write									No/Yes
Load Shed Rate Limit	LoadShedRateLim	AV	25	7044	71	ADF	157	29884	Read/Write		0.066	0	1 °F/min			0	1 °C/min	
Load Shed Adjust	LoadShedAdjust	AV	25	7045	72	ADF	158	29885	Read/Write		4	0	8 delta °F			0	4.4 delta °K	
Time to Next Occupancy Period	TimeToNextOcc	AV	25	7046	142	ADF	12	29837	Read Only				minutes				minutes	
Operating Mode	OprMode	MV	25	7047	299	ADI	18	29838	Read Only									0=Normal/1=Warmup/2=Cooldown/3=Coast
Cooling Weighting Parameter 1	CigWeight1	AV	25	7048	143	ADF	13	29839	Read Only									
Cooling Weighting Parameter 2	CigWeight2	AV	25	7049	144	ADF	14	29840	Read Only									
Heating Weighting Parameter 1	HtgWeight1	AV	25	7050	145	ADF	15	29841	Read Only									
Heating Weighting Parameter 2	HtgWeight2	AV	25	7051	146	ADF	16	29842	Read Only									
EWMA Cooling Demand	EWMAClgDmd	AV	25	7052	147	ADF	17	29843	Read Only									
EWMA Heating Demand	EWMAHtgDmd	AV	25	7053	148	ADF	18	29844	Read Only									
Corrected Return Time	CorrRetTime	AV	25	7054	149	ADF	19	29845	Read Only				minutes				minutes	
Uncorrected Return Time	UncorrRetTime	AV	25	7055	150	ADF	20	29846	Read Only				minutes				minutes	

Warmup Cooldown Start Time	WarmCoolStrtTime	AV	25	7056	151	ADF	21	29847	Read Only					minutes					minutes	
Warmup Cooldown Start Temperature	WarmCoolStrtTemp	AV	25	7057	152	ADF	22	29848	Read Only											
RAT Instead of Space-T	N/A	MV	25	7058					Read Only											No/Yes
Off During Unoccupied	OffDurUnocc	MV	25	7059	88	ADI	19	29914	Read/Write	No										No/Yes
Use Occupancy Schedule	UseOccSched	MV	25	7060		ADI	20		Read/Write	Yes										No/Yes
Direct Loadshed	DirLoadshd	MV	25	7061	128	ADI	111	29910	Read/Write	No										No/Yes
Redline	Redline	MV	25	7062	129	ADI	112	29911	Read/Write	No										No/Yes
PID Tuning Reset	PIDTunRst	MV	25	7063	130	ADI	113	29919	Read/Write											False/True
Adaptive Tuning Enable	N/A	MV	25	7064					Read/Write											Disable/Enable
Pre Occupancy Purge Enable	PreOccPurgeEna	MV	25	7065					Read/Write											Disable/Enable
Pre Occupancy Purge Time	PreOccPurgeTime	AV	25	7066					Read/Write		60	1	120	minutes				1	120	minutes
Pre Occupancy Purge Upper SAT Setpoint	PreOccUpSAT_SP	AV	25	7067					Read/Write		90	80	100	°F				26	38	°C
Pre Occupancy Purge Lower SAT Setpoint	PreOccLowSAT_SP	AV	25	7068					Read/Write		45	35	55	°F				1	13	°C
Unreliable Sensor Text	N/A	MV	25	7069					Read Only											No/Yes
No Reliable Zone Temp Alarm	N/A	MV	25	7070					Read Only											Normal/Alarm
Network Occupancy Timeout Enable	NetOccTimeoutEn	MV	25	7071					Read/Write											Disable/Enable
Network Occupancy Timeout Time	NetOccTimeoutTime	AV	25	7072					Read/Write			5	60	minutes						
Network Occupancy Request Time	N/A	AV	25	7073					Read Only					minutes						
Common Setpoint	Common-SP	AV	25	7074	853	ADF	189	30065	Read/Write			45	98	°F				8	36	°C
Heat Cool Setpoint Mode	HtgClgSP-Mode	MV	25	7075	852	ADI	188	30066	Read/Write											0=Common Setpoint/1=individual setpoints
Auto Changeover	N/A	AV	25	7076							3	2	5	delta °F				1.1	2.8	delta °C
Operational Outdoor Air Temperature	OprOAT	AV	26	7000	153	ADF	23	29541	Read Only		0			°F						°C
Outdoor Air Temperature Source	OATSrc	MV	26	7001	300	ADI	21	29542	Read Only	Unreliable										0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Outdoor Air Temperature Input	OAT	AV	26	7002					Read Only					°F						°C
Network Override Outdoor Air Temperature	NetOAT	AV	26	7003	6	ADF	24	29543	Read/Write			-50	125	°F				-18	52	°C
Operational Outdoor Air Humidity	OprOAH	AV	26	7004	154	ADF	25	29544	Read Only					%RH						%RH
Outdoor Air Enthalpy	OA-Enth	AV	26	7005	155	ADF	26	29545	Read Only					Btu/lb						kJ/kg
Outdoor Air Humidity Source	OAHSrc	MV	26	7006					Read Only											0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Outdoor Air Humidity Input	OAH	AV	26	7007					Read Only					%RH						%RH
Network Override Outdoor Air Humidity	NetOAH	AV	26	7008	7	ADF	27	29546	Read/Write			0	100	%RH				0	100	%RH
Operational Outdoor Air Quality	OprOAQ	AV	26	7009	156	ADF	28	29547	Read Only					ppm						ppm
Outdoor Air Quality Source	OAQSrc	MV	26	7010	301	ADI	22	29548	Read Only											0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Outdoor Air Quality Input	OAQ	AV	26	7011					Read Only					ppm						ppm
Outdoor Air Quality Sensor Range	OAQRange	AV	26	7012					Read/Write			0	5000	ppm				0	5000	ppm
Network Override Outdoor Air Quality	NetOAQ	AV	26	7013	8	ADF	29	29549	Read/Write			0	5000	ppm				0	5000	ppm
Outdoor Air Temperature Sensor Fault	N/A	MV	26	7014					Read Only											Normal/Alarm
Outdoor Air Humidity Sensor Fault	N/A	MV	26	7015					Read Only											Normal/Alarm
Outdoor Air Quality Sensor Fault	N/A	MV	26	7016					Read Only											Normal/Alarm
Operating Purge Command	OprPurgeCmd	MV	27	7000	381	ADI	98	29798	Read Only											False/True
Purge Command Source	PurgeCmdSrc	MV	27	7001	382	ADI	99	29799	Read Only											0=Unreliable/1=Local Input/2=Network Sensor/3=High Priority/4=BAS Override/5=Input Not Available
Local Purge Command Input	Purge	MV	27	7002	383	ADI	100	29800	Read Only											False/True
Network Override Purge Command	NetPurge	MV	27	7003	125	ADI	101	29801	Read/Write											False/True
Shutdown Input/Smoke Detector	SD	MV	27	7004	384	ADI	102	29802	Read Only											Normal/Alarm
Pressurize Instead of Purge	PressurizeNotPurge	MV	27	7005	844	ADI	192	30068	Read/Write											0=No/1=Yes
Self Test Command	N/A	MV	28	7000					Read/Write											State 0/State 1/State 2/State 3/State 4/State 5/State 6/State 7/State 8/State 9/State 10/State 11/State 12/State 13/State 14/State 15/State 16/State 17/State 18/State 19/State 20/State 21/State 22/State 23/State 24/State 25/State 26/State 27/State 28/State 29/State 30/State 31
Self Test Status	N/A	MV	28	7001					Read Only											State 0/State 1/State 2/State 3/State 4/State 5/State 6/State 7/State 8/State 9/State 10/State 11/State 12/State 13/State 14/State 15/State 16/State 17/State 18/State 19/State 20/State 21/State 22/State 23/State 24/State 25/State 26/State 27/State 28/State 29/State 30/State 31
Current Test	N/A	MV	28	7002					Read/Write											State 0/State 1/State 2/State 3/State 4/State 5/State 6/State 7/State 8/State 9/State 10/State 11/State 12/State 13/State 14/State 15/State 16/State 17/State 18/State 19/State 20/State 21/State 22/State 23/State 24/State 25/State 26/State 27/State 28/State 29/State 30/State 31
Self Test Time Remaining	N/A	AV	28	7003					Read Only											
Fan To Test	N/A	MV	28	7004					Read/Write											No/Yes
C1 To Test	N/A	MV	28	7005					Read/Write											No/Yes
C2 To Test	N/A	MV	28	7006					Read/Write											No/Yes
C3 To Test	N/A	MV	28	7007					Read/Write											No/Yes
C4 To Test	N/A	MV	28	7008					Read/Write											No/Yes
H1 To Test	N/A	MV	28	7009					Read/Write											No/Yes
H2 To Test	N/A	MV	28	7010					Read/Write											No/Yes
H3 To Test	N/A	MV	28	7011					Read/Write											No/Yes
Econ To Test	N/A	MV	28	7012					Read/Write											No/Yes
Exhaust To Test	N/A	MV	28	7013					Read/Write											No/Yes
Reset	N/A	MV	28	7014					Read/Write											No/Yes
Self Test Pause	N/A	MV	28	7015					Read/Write											No/Yes
Econ Prompt	N/A	MV	28	7016					Read/Write											No/Yes
Fan Prompt	N/A	MV	28	7017					Read/Write											No/Yes
Econ Answer	N/A	MV	28	7018					Read/Write	Wait										No/Yes/Wait
Fan Answer	N/A	MV	28	7019					Read/Write	Wait										No/Yes/Wait
Abort	N/A	MV	28	7020					Read/Write											No/Yes
State	N/A	MV	28	7021					Read Only											Off/Test Fan/Test C1/Test C2/Test C3/Test C4/Test H1/Test H2/Test H3/Test Econ/Test Exhaust
Fan State	FanResult	MV	28	7022					Read Only	Available										Stabilize/Wait/Check/Available/Not Run/Pass/Warning- Low DSP/Warning- SAT Not Dropped/Warning- SAT Not Increased/Warning- BSP Not Dropped/Warning/Fail- APS On Early/Fail- APS Off/Fail- Low Voltage/Fail- Low DSP/Fail- HPS/Fail- FRZ/Fail- LPS/Fail- LS/Fail- GV Off/Fail- Damper/Fail- SAT Unreliable/Fail- VFD Fault/Fail- Fan Overload/Fail/Fail- DSP Unreliable/Fail- BSP Unreliable

